

Declaration of Capacity of the Gas Transmission Pipeline System - SSGC (February- 2020)
(As per Format Schedule - II of TPA Rule, 2018)
Name of the Transporter : Sui Southern Gas Company

Entry Points - Transmission System										OGRA's Approved Gas Specifications											
Region	Description	Inlet Point	Contracted	Available	Status of Extra Capacity Available	Used by SSGC itself	Allocated to Shipper	Any Demand Pending with the Transactor		Inlet Pressure	GCV (Min)	Temp (Max)	W1* (Min)	Sulfur (Max)	H2S (Max)	CO2 (Max)	N2 (Max)	O2 (Max)	Water Content (Max)	HCDP (Max)	
										PSIG	BTU/scf	Deg F	BTU/scf	Grain/100 Scf	Grain/100 Scf	Mole %	Mole %	Mole %	Lbs/MMCF	Deg F	Deg F
1	Sukkur Region	Nawabshah	-	10	Interruptible Basis	36	Nil	Nil		775	900	120	1180	3.5	0.24	3	7	0.2	7	32	
2	Hyderabad Region	Golarchi	-	35	Interruptible Basis	61	Nil	23		1000	900	120	1180	3.5	0.24	3	7	0.2	7	32	
3	ILBP Region	Nawabshah	-	0	N/A	668	Nil	Nil		775-1000	900	120	1180	3.5	0.24	3	7	0.2	7	32	
4	IRBP Region	Pakland	-	30	Interruptible Basis	80	Nil	Nil		1200	900	120	1180	3.5	0.24	3	7	0.2	7	32	
5	Karachi Region	Pakland		120	Interruptible Basis	284	Nil	Nil		1200	900	120	1180	3.5	0.24	3	7	0.2	7	32	
6	Quetta Region	Shikarpur (SKP)	-	0	N/A	190	Nil	Nil		1100	900	120	1180	3.5	0.24	3	7	0.2	7	32	
7	SSGPL (42" dia RLNG Pipeline)	CTS Bin Qasim	-	0	N/A	1200 (SSGPL)	Nil	Nil		1200	RLNG Specifications										

* ± 5% variation on the basis of Specific Gravity
Note-1: If new Entry Point(s) other than the existing entry points are required on SSGC Transmission network, then the same shall be reviewed on case to case to basis keeping in view the location, operational constraints, seasonal load and available capacity in respective pipeline segments.
Note-2: The Exit Points of Transmission network are Sales Meter Stations

Declaration of Capacity of the Gas Transmission Pipeline System - SSGC (February- 2020)
(As per Format Schedule - II of TPA Rule, 2018)
Name of the Transporter : Sui Southern Gas Company

Exit Points - Transmission System

Exit Points - Transmission System									Actual Gas Specifications										
Region	Description	Exit Point	Contracted	Available	Status of Extra Capacity Available	Used by Transporter	Allocated to Shipper	Any Demand Pending with the Transporter	Delivery Pressure	GCV	Temp (Max)	WI*	Sulfur (Max)	H2S	CO2	N2	O2 (Max)	Water Content	HCDP (Max)
									PSIG	BTU/Scf	Deg F	BTU/Scf	Grain/100 Scf	Grain/100 Scf	Mole%	Mole%	Mole%	Lbs/MMCF	Deg F
1	Sukkar Region	Sukkar	-	10	Interruptible Basis	Yes	Nil	No	100	1010.3	120	1231	3.5	0.1	2.828	7.305	0.2	2	32
2a	Hyderabad Region	TM Khan	-	2	Interruptible Basis	Yes	Nil	Yes	100	1070.3	120	1327	3.5	0.1	2.62	1.393	0.2	1.5	32
2b		Hyderabad	-	33	Interruptible Basis	Yes	Nil	Yes	100	962.4	120	1208	3.5	0.1	2.889	5.876	0.2	2.5	32
3a	ILBP Regions	Nawabshah	-	0	N/A	Yes	Nil	No	100	1010.3	120	1231	3.5	0.1	2.828	7.305	0.2	2	32
3b		Tando Adam	-	0	N/A	Yes	Nil	No	100	953.9	120	1141	3.5	0.15	3.587	11.785	0.2	2.5	32
3c		Thatta	-	0	N/A	Yes	Nil	No	100	983.1	120	1212	3.5	0.1	3.097	6.613	0.2	1	32
3d		Dhabeji	-	0	N/A	Yes	Nil	No	100	960.8	120	1206	3.5	0.1	6.179	5.498	0.2	2.5	32
4b	IRBP Regions	Nooriabad	-	10	Interruptible Basis	Yes	Nil	Yes	120	927.3	120	1182	3.5	0	1.258	8.720	0.2	1.5	32
4c		Dadu	-	10	Interruptible Basis	Yes	Nil	Yes	100	913.0	120	1156	3.5	0	1.454	10.374	0.2	1	32
4d		Shikarpur	-	10	Interruptible Basis	Yes	Nil	Yes	100	955.0	120	1232	3.5	0.3	0.365	7.201	0.2	2	32
5	Karachi Region	Karachi (FJFC)	-	120	Interruptible Basis	Yes	Nil	No	100	1005.2	120	1259	3.5	0.1	2.062	4.919	0.2	2.5	32
6	Quetta Region	Quetta	-	0	N/A	Yes	Nil	No	120	954.4	120	1218	3.5	0.2	0.754	7.81	0.2	1.5	32
7	SNGPL (42" dia RLNG Pipeline)	SNGPL at Sawan	-	0	N/A	1200 (SNGPL)	Nil	No	1115	RLNG Specifications									

* ± 5% variation on the basis of Specific Gravity

Note-1: If new Entry Point(s), other than the existing entry points are required on SSGC Transmission network, then the same shall be reviewed on case to case to basis keeping in view the location, operational constraints, seasonal load and available capacity in respective pipeline segments.

Note-2: The Exit Points of Transmission network are Sales Meter Stations