

Declaration of Capacity of the Gas Transmission Pipeline System - SSGC (April- 2020)

(As per Format Schedule - II of TPA Rule, 2018)

Name of the Transporter : Sui Southern Gas Company

Entry Points - Transmission System

Region	Description	Inlet Point	Contracted	Available	Status of Extra Capacity Available	Used by SSGC itself	Allocated to Shipper	Any Demand Pending with the Transporter	Gas Specifications										
									Inlet Pressure	GCV (Min)	Temp (Max)	WI* (Min)	Sulfur (Max)	H2S (Max)	CO2 (Max)	N2 (Max)	O2 (Max)	Water Content (Max)	HCDP (Max)
									PSIG	BTU/Scf	Deg F	BTU/Scf	Grain/100 Scf	Grain/100 Scf	Mole%	Mole%	Mole%	Lbs/MMCF	Deg F
1	Sukkur Region	Nawabshah	-	10	Interruptible Basis	36	Nil	Nil	775	900	120	1180	3.5	0.24	3	7	0.2	7	32
2	Hyderabad Region	Golarchi	-	35	Interruptible Basis	61	Nil	23	1000	900	120	1180	3.5	0.24	3	7	0.2	7	32
3	ILBP Region	Nawabshah	-	0	N/A	668	Nil	Nil	775-1000	900	120	1180	3.5	0.24	3	7	0.2	7	32
4	IRBP Region	Pakland	-	30	Interruptible Basis	80	Nil	Nil	1200	900	120	1180	3.5	0.24	3	7	0.2	7	32
5	Karachi Region	Pakland		120	Interruptible Basis	284	Nil	Nil	1200	900	120	1180	3.5	0.24	3	7	0.2	7	32
6	Quetta Region	Shikarpur (SKP)	-	70	N/A	120	Nil	Nil	1100	900	120	1180	3.5	0.24	3	7	0.2	7	32
7	SNGPL (42" dia RLNG Pipeline)	CTS Bin Qasim	-	0	N/A	1200 (SNGPL)	Nil	Nil	1200	RLNG Specifications									

* ± 5% variation on the basis of Specific Gravity

Note-1: If new Entry Point(s), other than the existing entry points are required on SSGC Transmission network, then the same shall be reviewed on case to case to basis keeping in view the location, operational constraints, seasonal load and available capacity in respective pipeline segments.

Declaration of Capacity of the Gas Transmission Pipeline System - SSGC (April- 2020)

(As per Format Schedule - II of TPA Rule, 2018)

Name of the Transporter : Sui Southern Gas Company

Exit Points - Transmission System

Region	Description	Exit Point	Contracted	Available	Status of Extra Capacity Available	Used by Transporter	Allocated to Shipper	Any Demand Pending with the Transporter	Gas Specifications										
									Delivery Pressure	GCV (Min)	Temp (Max)	W1* (Min)	Sulfur (Max)	H2S (Max)	CO2 (Max)	N2 (Max)	O2 (Max)	Water Content (Max)	HCDP (Max)
									PSIG	BTU/Scf	Deg F	BTU/Scf	Grain/100 Scf	Grain/100 Scf	Mole%	Mole%	Mole%	Lbs/MMCF	Deg F
1	Sukkar Region	Sukkar	-	10	Interruptible Basis	Yes	Nil	No	100	1015	120	1237	3.5	0.15	2.69	7.228	0.2	2	32
2a	Hyderabad Region	TM Khan	-	2	Interruptible Basis	Yes	Nil	Yes	100	1051.3	120	1303	3.5	0.1	2.936	2.023	0.2	1	32
2b		Hyderabad	-	33	Interruptible Basis	Yes	Nil	Yes	100	969	120	1219	3.5	0	2.842	5.437	0.2	1	32
3a	ILBP Regions	Nawabshah	-	0	N/A	Yes	Nil	No	100	1015	120	1237	3.5	0.15	2.69	7.228	0.2	2	32
3b		Tando Adam	-	0	N/A	Yes	Nil	No	100	964.5	120	1162	3.5	0.2	2.863	11.311	0.2	2	32
3c		Thatta	-	0	N/A	Yes	Nil	No	100	978.9	120	1210	3.5	0.1	2.756	7.015	0.2	1	32
3d		Dhabeji	-	0	N/A	Yes	Nil	No	100	969	120	1220	3.5	0	2.796	5.388	0.2	1.5	32
4b	IRBP Regions	Nooriabad	-	10	Interruptible Basis	Yes	Nil	Yes	120	923.1	120	1174	3.5	0	1.359	9.095	0.2	1.5	32
4c		Dadu	-	10	Interruptible Basis	Yes	Nil	Yes	100	918.8	120	1131	3.5	0.1	1.877	12.717	0.2	1.5	32
4d		Shikarpur	-	10	Interruptible Basis	Yes	Nil	Yes	100	955.3	120	1233	3.5	0.25	0.198	7.188	0.2	2.5	32
5	Karachi Region	Karachi (FJFC)	-	120	Interruptible Basis	Yes	Nil	No	100	962.2	120	1207	3.5	0	2.463	6.49	0.2	1.5	32
6	Quetta Region	Quetta	-	70	N/A	Yes	Nil	No	120	960.1	120	1233	3.5	0.23	0.365	7.29	0.2	2.5	32
7	SNGPL (42" dia RLNG Pipeline)	SNGPL at Sawan	-	0	N/A	1200 (SNGPL)	Nil	No	1115	RLNG Specifications									

* ± 5% variation on the basis of Specific Gravity

Note-1: If new Exit Point(s), other than the existing exit points are required on SSGC Transmission network, then the same shall be reviewed on case to case to basis keeping in view the location, operational constraints, seasonal load and available capacity in respective pipeline segments.

Note-2: The Exit Points of Transmission network are Sales Meter Stations