

ENTRY AND EXIT POINT CAPACITY- DISTRIBUTION NETWORK - KARACHI (SOUTH) (Available for July-2020)

Sr. No.	Region Name	Entry Points*		Exit Points					Gas Quality Parameters				Remarks
		Sales Meter Station Name	SMS Capacity	Operating Pressure	Capacity of Supply Mains**	Committed / Contractual Load	Allocated to Shipper	Available (spare) Capacity in Supply Mains**	GCV	WI	N2	CO2	
			MMCFD	PSIG	MMCFD	MMCFD		MMCFD					
1	Karachi (East)	FJFC	240	150	202 ^(a)	225	Nil	Nil	As measured in Transmission system by relevant deptt. of SSGC				
2	Karachi (East)	FFBQL	240	150	229 ^(ab)	200	Nil	29					
3	Karachi (West)	ACPL-12"	50	300	25 ^(ab)	57	Nil	Nil					
4	Karachi (East)	Pakland	15	150	6 ^(ac)	10	Nil	Nil					

^(a) 30" dia. Supply Main Header feeding Bin Qasim Industrial Area & Korangi + Landhi Industrial Area.

^(ab) 42" dia. Supply Main Header feeding M/s KE, Bin Qasim.

^(ab) 12" dia. Supply Main Header feeding Hub Industrial Area.

^(ac) 8" dia. Supply Main Header feeding M/s Pakland Cement (M/s Dewan Cement).

* The Entry Points of Distribution Network are the Sales Meter Stations (SMSs).

Notes:

- A) Capacities at remaining SMSs (i.e. SMSs with dominant Industrial Sale) are being worked out and will be notified accordingly.
- B) The available (spare) capacities in Distribution network will be offered to shipper on "Interruptible Basis".
- C) Total available capacity in distribution network will depend upon the total available capacity in relevant segment of transmission network.