

ENTRY AND EXIT POINT CAPACITY- SUPPLY MAINS OF DISTRIBUTION SYSTEM - BALOCHISTAN REGION

Jun 21

Sr. No.	Region Name	Entry Points		Exit Points					Gas Specifications					Remarks
		Sales Meter Station Name	SMS Operational Capacity	Operational Pressure for Capacity Calculation	Capacity of Supply Mains	Committed / Contractual Load	Allocated to Shipper	Available (spare) Capacity in Supply Mains	GCV	WI	Temp	N2	CO2	
1	Quetta	SMS Quetta / SMS Rakhshan / SMS Spezend / SMS HCPC	205	80	85.000	63.063	Nil	Nil	As measured in Transmission System by relevant department of SSGC	-				
2	Quetta	SMS Mach		20	4.000	0.362	Nil	Nil		-				
3	Quetta	SMS Kolpur		10	2.000	0.077	Nil	Nil		-				
4	Quetta	SMS Belpat		15	3.000	0.308	Nil	Nil		-				
5	Quetta	SMS Sibi		30	8.000	0.797	Nil	Nil		-				
6	Quetta	SMS Dhader		15	3.000	0.177	Nil	Nil		-				
7	Quetta	SMS Jhatpat		60	10.000	1.806	Nil	Nil		-				
8	Quetta	SMS Dera Murad Jamali		40	5.000	0.594	Nil	Nil		-				
9	Quetta	SMS Sobatpur		30	5.000	1.359	Nil	Nil		-				

Important Notes :

*Calculated capacities of Supply Mains i.e. downstream of SMSs may change depending upon location and demand of customers. For modification/extension/expansion of network, the shipper will be required to bear the cost (including allied cost) to meet capacity requirements as per Rule4 (k) of TPA Rules, 2018 provided it is technically/operationally feasible for the Company. Request for transportation service at any specific location based on available (spare) Capacity on Supply Mains of Distribution System will be evaluated by the Transporter on case to case basis, keeping in view the system operational constraints, system integrity, location and time of the year in line with provisions of Schedule II of TPA Rules, 2018 and Appendix E (Capacity Allocation Methodology) of Pakistan Gas Network Code.

*The available (spare) capacities in Supply Mains of Distribution System will be offered to shipper on 'Interruptible Basis.

*Total available capacity in Supply mains of distribution system will depend upon the total available capacity in relevant segment of transmission network.