

Annexure – A

To be provided on non-judicial stamp paper of PKR. 100/-

Specimen

Undertaking

INTERNAL HOUSELINE INSTALLATION COMPLETION REPORT

I certify that internal gas pipelines fitting (house line installation) have been completed in accordance with OGRA specifications and Standards for materials in as per house line plan issued by the Company against my Application/Customer No. _____ dated _____ and tested at a pressure of 10 PSIG for fifteen minutes and is found free from leakage to entire satisfaction

Gas appliances, as per details given below, have also been fitted. I shall not hold M/s Sui Sothern Gas Company responsible for any leakage(s) and or consequential damages to life or property which may occur due to extreme weather effects, workmanship, wear and tear, man-handling of gas pipelines etc. The appliances at my premises have been installed / points plugged where appliances not installed.

Details of Gas Appliances:

Cooking Burners/Equipments: _____

Water Heater/Geyser: _____

Signature of the Customer: _____

CNIC No _____

Name & Address: _____

Dated: _____

Annexure – B

General Guidelines for Information of Domestic, Commercial Customers for Laying of Internal Gas Houseline.

G I PIPE (Galvanized Iron Pipe):

Galvanized pipe ½ inch diameter shall be formed in accordance with the requirement of BS 1387 medium grade (Latest edition). Pipe end shall be supplied with threaded end conforming to BS-21 taper pipe thread.

Specifications:

Nominal Dia	Outside Dia Maximum	Minimum	Wall thickness Tolerance %
½ inch	0.856 inch	0.831 inch	+ -10
¾ inch	1.072 inch	1.047 inch	+ -10
1 inch	1.346 inch	1.316 inch	+ -10
2 inch	2.394 inch	0.144 inch	+ -10

Malleable Cast Iron Threaded Fitting:

(Union, Elbow, Concentric Reducer, Bush, Cap, Tee, Socket and Hex Nipple etc.)

All screwed fittings under this Specifications shall be made from forged carbon steel sizes ranging from 1/2 to 2-inch diameter conforming to British Standard Specifications BS-143.

Only Metallic Pipes (GI Pipes OGRA specifications) are allowed. Installation of gas pipelines in solid walls / partitions is not allowed. No gas pipe shall be installed underground in concrete / cement floors.

Customer houseline is required to be laid in accordance with prevailing OGRA standards.